

Performance of the ducted silencers**FVS 160-1000****FVS 160-600****FVS 160-300**

Requested by	Flexovent OÜ Mart Petermann Kadaka tee 70a 12618, Tallinn ESTONIA mart.petermann@flexovent.ee
Order ref.	Mart Petermann, 20.12.2021, EF4APT210087-03
Contact person	Eurofins Expert Services Oy Pekka Kettunen Tekniikantie 4B 02150 Espoo tel. +358 40 159 6471 PekkaKettunen@eurofins.fi
Assignment	Determination of the performance of the ducted silencer FVS 160-1000/600/300
Sample details	The customer delivered the silencer, the specifications of which are in appendix 1. Samples were received 5.1.2022. Measurements were carried out 31.1-1.2.2022.
Methods	Total pressure loss measurements, flow noise measurements and insertion loss measurements were carried out according to ISO 7235:2003 /1/. Description of the test facility is presented in appendix 2. Air flow rates were measured according to ISO 5167-1:2003 and ISO 5167-2:2003 /2/ using orifice plates with corner tapings. FINAS Finnish Accreditation Service has accredited our laboratory (T001) to perform measurements according to standards ISO 7235:2003, ISO 5167-1:2003 and ISO 5167-2:2003. Other measurements mentioned in this test report do not belong to the field of accreditation.

Results	<p>Measurement results are presented in appendix 3-5. Measurement results are valid only for the tested samples.</p> <p>Instruments used in measurements are presented in appendix 6.</p>
References	<p>/1/ ISO 7235:2003. Acoustics - Laboratory measurement procedures for ducted silencers and air-terminal units - Insertion loss, flow noise and total pressure loss.</p> <p>/2/ ISO 5167-1:2003. Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full. Part 1: General principles and requirements.</p> <p>ISO 5167-2:2003. Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full. Part 2: Orifice plates.</p>

Espoo, 1.2.2022



Pekka Kettunen
Pekka Kettunen
Expert



Mika Hurme
Mika Hurme
Expert

Appendices	6
Distribution	Customer, electronically approved

Ducted silencer: FVS 160-1000/600/300

Description of the sample

ISO 7235:2003


Symbols and units	FVS 160-1000	FVS 160-600	FVS 160-300	Substitution duct
Type	Ducted silencer			Spiral duct
Diameter of the inlet and outlet sections Ød, mm	160			160
Width a, mm	240			-
Height b, mm	215			-
Length L, mm	1000	600	300	1000 / 600 / 300
Mass, kg	8.22	5.25	3.26	-
Thickness of steel duct material, mm	0.7			0.7
Direction of flow determined	no			no
Direction of insertion loss	no			no



Ducted silencer: FVS 160-1000/600/300

Test facility


ISO 7235:2003



Components:	Symbols and units	Length
1. Transition $\varnothing 1600 / \varnothing 160$	L_1 , mm	5580
2. Duct $\varnothing 160$	L_2 , mm	2000/2000/1500
3. Silencer	L , mm	300/600/1000
4. Duct $\varnothing 160$	L_4 , mm	2500
5. Transition $\varnothing 160 / \varnothing 1250$	L_5 , mm	4260
Total length of measurement duct		14640 / 14940 / 14840

Volume of the reverberation room is 298 m³.

Microphone location in the reverberation room



Symbol	Unit	Distance
L_{x1}	m	2.0
L_{y1}	m	3.6
h_1	m	2.7
L_{x2}	m	3.7
L_{y2}	m	2.1
h_2	m	2.6
L_{x3}	m	4.0
L_{y3}	m	4.1
h_3	m	3.9

Symbols and units

- L_x Distance from wall, m
- L_y Distance from wall, m
- h Distance from floor, m

Ducted silencer: FVS 160-1000/600/300

Test facility

ISO 7235:2003

Volume of the reverberation room: 298 m³

Reverberation time T of the reverberation room and the transmission coefficient τ of the measurement duct transmission element Ø 160.

Symbol	Unit	T	Symbol	Unit	τ
T ₅₀	s	5.15	τ_{50}	-	0.730
T ₆₃	s	5.51	τ_{63}	-	0.730
T ₈₀	s	3.82	τ_{80}	-	0.971
T ₁₀₀	s	3.85	τ_{100}	-	0.922
T ₁₂₅	s	6.28	τ_{125}	-	0.949
T ₁₆₀	s	5.19	τ_{160}	-	0.987
T ₂₀₀	s	5.72	τ_{200}	-	0.997
T ₂₅₀	s	5.25	τ_{250}	-	0.997
T ₃₁₅	s	5.71	τ_{315}	-	0.997
T ₄₀₀	s	4.21	τ_{400}	-	0.997
T ₅₀₀	s	5.17	τ_{500}	-	0.997
T ₆₃₀	s	4.43	τ_{630}	-	0.997
T ₈₀₀	s	5.44	τ_{800}	-	0.997
T ₁₀₀₀	s	5.68	τ_{1000}	-	0.997
T ₁₂₅₀	s	4.94	τ_{1250}	-	0.997
T ₁₆₀₀	s	4.14	τ_{1600}	-	1.000
T ₂₀₀₀	s	3.91	τ_{2000}	-	1.000
T ₂₅₀₀	s	3.11	τ_{2500}	-	1.000
T ₃₁₅₀	s	2.39	τ_{3150}	-	1.000
T ₄₀₀₀	s	2.06	τ_{4000}	-	1.000
T ₅₀₀₀	s	1.62	τ_{5000}	-	1.000
T ₆₃₀₀	s	1.30	τ_{6300}	-	1.000
T ₈₀₀₀	s	1.03	τ_{8000}	-	1.000
T ₁₀₀₀₀	s	0.69	τ_{10000}	-	1.000

Transmission coefficient τ has not been measured at frequencies below 50 Hz.

Symbols and units

- T_{50...10000} Reverberation time, s
- $\tau_{50...10000}$ Transmission coefficient, -
- 50...10000 Centre frequency of one-third octave band, Hz



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Ducted silencer: FVS 160-1000/600/300


Limiting insertion loss of the test facility

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 14840 mm

Symbol	Unit	D
D _{1/3oct50}	dB	53.5
D _{1/3oct63}	dB	55.5
D _{1/3oct80}	dB	59.5
D _{1/3oct100}	dB	61.0
D _{1/3oct125}	dB	65.5
D _{1/3oct160}	dB	66.0
D _{1/3oct200}	dB	70.5
D _{1/3oct250}	dB	70.5
D _{1/3oct315}	dB	74.5
D _{1/3oct400}	dB	72.5
D _{1/3oct500}	dB	70.0
D _{1/3oct630}	dB	70.0
D _{1/3oct800}	dB	63.5
D _{1/3oct1000}	dB	59.5
D _{1/3oct1250}	dB	59.5
D _{1/3oct1600}	dB	65.5
D _{1/3oct2000}	dB	66.0
D _{1/3oct2500}	dB	65.0
D _{1/3oct3150}	dB	63.5
D _{1/3oct4000}	dB	60.5
D _{1/3oct5000}	dB	59.0
D _{1/3oct6300}	dB	51.0
D _{1/3oct8000}	dB	49.0
D _{1/3oct10000}	dB	44.0



Symbols and units

D_{1/3oct50...10000} Insertion loss in one-third octave bands, dB
 50...10000 Centre frequency of one third octave band, Hz



The results are only valid for the tested sample(s).
 This report may be published in its entirety, parts of it only with a written permission by Eurofins

Ducted silencer: FVS 160-1000/600/300


Limiting insertion loss of the test facility

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 14840 mm

Symbol	Unit	D
D_{oct63}	dB	56
D_{oct125}	dB	64
D_{oct250}	dB	72
D_{oct500}	dB	71
$D_{oct1000}$	dB	61
$D_{oct2000}$	dB	66
$D_{oct4000}$	dB	61
$D_{oct8000}$	dB	47



Symbols and units

$D_{oct63...8000}$ Insertion loss in octave bands, dB
 63...8000 Centre frequency of octave band, Hz

Ducted silencer: FVS 160-1000


Insertion loss in one-third octave bands

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 1000 mm

Symbol	Unit	Di
D _{1/3oct50}	dB	3
D _{1/3oct63}	dB	6
D _{1/3oct80}	dB	12
D _{1/3oct100}	dB	19
D _{1/3oct125}	dB	14
D _{1/3oct160}	dB	10
D _{1/3oct200}	dB	14
D _{1/3oct250}	dB	23
D _{1/3oct315}	dB	27
D _{1/3oct400}	dB	31
D _{1/3oct500}	dB	36
D _{1/3oct630}	dB	40
D _{1/3oct800}	dB	45
D _{1/3oct1000}	dB	50
D _{1/3oct1250}	dB	>50
D _{1/3oct1600}	dB	>50
D _{1/3oct2000}	dB	>50
D _{1/3oct2500}	dB	>50
D _{1/3oct3150}	dB	>50
D _{1/3oct4000}	dB	46
D _{1/3oct5000}	dB	37
D _{1/3oct6300}	dB	28
D _{1/3oct8000}	dB	24
D _{1/3oct10000}	dB	21



Symbols and units

- Di Insertion loss, dB
- D_{1/3oct50...10000} Insertion loss in one-third octave bands, dB
- 50...10000 Centre frequency of one-third octave band, Hz



The results are only valid for the tested sample(s).
 This report may be published in its entirety, parts of it only with a written permission by Eurofins

Ducted silencer: FVS 160-1000


Insertion loss in octave bands

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 1000 mm

Symbol	Unit	Di
$D_{\text{oct}63}$	dB	6
$D_{\text{oct}125}$	dB	13
$D_{\text{oct}250}$	dB	18
$D_{\text{oct}500}$	dB	34
$D_{\text{oct}1000}$	dB	48
$D_{\text{oct}2000}$	dB	>50
$D_{\text{oct}4000}$	dB	41
$D_{\text{oct}8000}$	dB	23



Symbols and units

- Di Insertion loss, dB
- $D_{\text{oct}63 \dots 8000}$ Insertion loss in octave bands, dB
- 63...8000 Centre frequency of octave band, Hz

Ducted silencer: FVS 160-1000


Pressure loss and flow noise in octave bands

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 1000 mm

Air density 1,20 kg/m³



Symbol	Unit	1	2	3	4	5	6	7
q_v	dm ³ /s	38.2	57.2	91.7	125	156	193	240
v_{al}	m/s	1.9	2.8	4.6	6.2	7.8	9.6	11.9
p_{tot}	Pa	1.7	3.8	9.0	16.0	24.6	36.4	55.2
ζ_{tot}	-	0.80	0.78	0.72	0.69	0.68	0.66	0.65
L_{W63}	dB	*	*	*37.1	43.5	47.7	50.5	54.7
L_{W125}	dB	*	*	36.1	41.6	46.3	51.2	55.6
L_{W250}	dB	*	*	31.5	37.8	41.8	46.1	50.9
L_{W500}	dB	*	*	25.3	33.2	38.2	42.5	46.9
L_{W1000}	dB	*	*	*17	26.3	32.5	37.8	42.9
L_{W2000}	dB	*	*	*14.5	*22.5	30.0	36.3	42.2
L_{W4000}	dB	*	*	*19.8	*20.5	*24.5	*31.2	38.4
L_{W8000}	dB	*	*	*26.4	*26.4	*26.4	*27	*30.1
L_W	dB	*	*	*40.6	46.7	51.0	55.0	59.4
L_{WA}	dB(A)	*	*	*29.6	*35	39.9	44.8	49.9

*) The background noise requirements of standard ISO 3741:2010 have not been met.

Data represent upper bounds to the sound power level of the noise source under test.

Symbols and units

- q_v Air volume flow rate, dm³/s
- v_{al} Duct velocity (ø160 mm duct), m/s
- p_{tot} Total pressure loss, Pa
- ζ_{tot} Total pressure loss coefficient, -
- $L_{W63...8000}$ Sound power level in the duct in octave bands, dB
- 63...8000 Centre frequencies of the octave bands, Hz
- L_W Sound power level in the duct, dB
- L_{WA} A-weighted sound power level in the duct, dB(A)



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Ducted silencer: FVS 160-600


Insertion loss in one-third octave bands

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 600 mm

Symbol	Unit	Di
D _{1/3oct50}	dB	0
D _{1/3oct63}	dB	2
D _{1/3oct80}	dB	6
D _{1/3oct100}	dB	9
D _{1/3oct125}	dB	10
D _{1/3oct160}	dB	6
D _{1/3oct200}	dB	7
D _{1/3oct250}	dB	13
D _{1/3oct315}	dB	14
D _{1/3oct400}	dB	17
D _{1/3oct500}	dB	18
D _{1/3oct630}	dB	23
D _{1/3oct800}	dB	25
D _{1/3oct1000}	dB	28
D _{1/3oct1250}	dB	30
D _{1/3oct1600}	dB	33
D _{1/3oct2000}	dB	34
D _{1/3oct2500}	dB	34
D _{1/3oct3150}	dB	34
D _{1/3oct4000}	dB	27
D _{1/3oct5000}	dB	21
D _{1/3oct6300}	dB	17
D _{1/3oct8000}	dB	14
D _{1/3oct10000}	dB	14



Symbols and units

- Di Insertion loss, dB
- D_{1/3oct50...10000} Insertion loss in one-third octave bands, dB
- 50...10000 Centre frequency of one-third octave band, Hz



The results are only valid for the tested sample(s).
 This report may be published in its entirety, parts of it only with a written permission by Eurofins

Ducted silencer: FVS 160-600


Insertion loss in octave bands

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 600 mm

Symbol	Unit	Di
$D_{\text{oct}63}$	dB	2
$D_{\text{oct}125}$	dB	8
$D_{\text{oct}250}$	dB	10
$D_{\text{oct}500}$	dB	19
$D_{\text{oct}1000}$	dB	27
$D_{\text{oct}2000}$	dB	34
$D_{\text{oct}4000}$	dB	25
$D_{\text{oct}8000}$	dB	15



Symbols and units

- Di Insertion loss, dB
- $D_{\text{oct}63 \dots 8000}$ Insertion loss in octave bands, dB
- 63...8000 Centre frequency of octave band, Hz

Ducted silencer: FVS 160-600


Pressure loss and flow noise in octave bands

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 600 mm

Air density 1,20 kg/m³



Symbol	Unit	1	2	3	4	5	6	7
q _v	dm ³ /s	42.8	71.5	95.8	120	151	192	244
v _{al}	m/s	2.1	3.6	4.8	6.0	7.5	9.6	12.1
p _{tot}	Pa	1.5	3.9	6.9	10.2	15.7	24.6	39.0
ζ _{tot}	-	0.53	0.51	0.51	0.48	0.46	0.45	0.44
L _{W63}	dB	*	*36.9	40.8	43.9	48.4	52.5	56.2
L _{W125}	dB	*	36.1	40.3	44.0	47.8	52.3	56.2
L _{W250}	dB	*	31.4	37.8	42.1	46.0	49.9	53.9
L _{W500}	dB	*	25.7	34.1	39.3	44.0	48.5	52.5
L _{W1000}	dB	*	*15.9	24.9	31.7	37.8	43.6	48.7
L _{W2000}	dB	*	*14.5	*18.1	*25.8	33.6	40.8	47.0
L _{W4000}	dB	*	*19.7	*20	*20.9	*25.5	33.5	41.5
L _{W8000}	dB	*	*26	*26.2	*26.2	*26.3	*26.7	*30.2
L _W	dB	*	*40.5	45.1	48.8	53.1	57.4	61.4
L _{WA}	dB(A)	*	*29.6	*34.7	39.5	44.5	49.6	54.5

*) The background noise requirements of standard ISO 3741:2010 have not been met.

Data represent upper bounds to the sound power level of the noise source under test.

Symbols and units

- q_v Air volume flow rate, dm³/s
- v_{al} Duct velocity (ø160 mm duct), m/s
- p_{tot} Total pressure loss, Pa
- ζ_{tot} Total pressure loss coefficient, -
- L_{W63...8000} Sound power level in the duct in octave bands, dB
- 63...8000 Centre frequencies of the octave bands, Hz
- L_W Sound power level in the duct, dB
- L_{WA} A-weighted sound power level in the duct, dB(A)



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Ducted silencer: FVS 160-300


Insertion loss in one-third octave bands

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 300 mm

Symbol	Unit	Di
D _{1/3oct50}	dB	1
D _{1/3oct63}	dB	1
D _{1/3oct80}	dB	2
D _{1/3oct100}	dB	4
D _{1/3oct125}	dB	4
D _{1/3oct160}	dB	5
D _{1/3oct200}	dB	3
D _{1/3oct250}	dB	4
D _{1/3oct315}	dB	6
D _{1/3oct400}	dB	8
D _{1/3oct500}	dB	8
D _{1/3oct630}	dB	9
D _{1/3oct800}	dB	9
D _{1/3oct1000}	dB	10
D _{1/3oct1250}	dB	11
D _{1/3oct1600}	dB	12
D _{1/3oct2000}	dB	12
D _{1/3oct2500}	dB	12
D _{1/3oct3150}	dB	14
D _{1/3oct4000}	dB	11
D _{1/3oct5000}	dB	8
D _{1/3oct6300}	dB	5
D _{1/3oct8000}	dB	7
D _{1/3oct10000}	dB	7



Symbols and units

- Di Insertion loss, dB
- D_{1/3oct50...10000} Insertion loss in one-third octave bands, dB
- 50...10000 Centre frequency of one-third octave band, Hz



The results are only valid for the tested sample(s).
 This report may be published in its entirety, parts of it only with a written permission by Eurofins

Ducted silencer: FVS 160-300


Insertion loss in octave bands

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 300 mm

Symbol	Unit	Di
$D_{\text{oct}63}$	dB	1
$D_{\text{oct}125}$	dB	4
$D_{\text{oct}250}$	dB	4
$D_{\text{oct}500}$	dB	8
$D_{\text{oct}1000}$	dB	10
$D_{\text{oct}2000}$	dB	12
$D_{\text{oct}4000}$	dB	10
$D_{\text{oct}8000}$	dB	6



Symbols and units

- Di Insertion loss, dB
- $D_{\text{oct}63 \dots 8000}$ Insertion loss in octave bands, dB
- 63...8000 Centre frequency of octave band, Hz

Ducted silencer: FVS 160-300


Pressure loss and flow noise in octave bands

ISO 7235:2003

Diameter of the inlet and outlet sections: 160 mm

Length: 300 mm

Air density 1,20 kg/m³



Symbol	Unit	1	2	3	4	5	6	7
q _v	dm ³ /s	61.7	74.4	97.1	128	161	204	254
v _{al}	m/s	3.1	3.7	4.8	6.4	8.0	10.1	12.6
p _{tot}	Pa	2.0	2.9	4.9	8.2	12.6	20.1	31.6
ζ _{tot}	-	0.35	0.35	0.35	0.34	0.33	0.33	0.33
L _{W63}	dB	*	*34.8	39.8	45.7	48.4	52.5	57.0
L _{W125}	dB	*	34.2	38.2	43.4	48.1	52.5	56.8
L _{W250}	dB	*	31.2	36.0	40.7	44.8	48.8	53.2
L _{W500}	dB	*	27.7	33.9	39.6	43.8	47.8	51.6
L _{W1000}	dB	*	*15.8	24.7	32.9	38.5	43.8	48.5
L _{W2000}	dB	*	*13.6	*17.2	*27.4	35.3	42.3	47.7
L _{W4000}	dB	*	*19.9	*19.9	*21.2	*26.7	35.5	43.0
L _{W8000}	dB	*	*26.1	*26.1	*26.2	*26.3	*27.4	*31.6
L _W	dB	*	*39.1	43.7	49.2	53.0	57.3	61.7
L _{WA}	dB(A)	*	*29.8	*34.1	39.7	44.6	49.7	54.5

*) The background noise requirements of standard ISO 3741:2010 have not been met.

Data represent upper bounds to the sound power level of the noise source under test.

Symbols and units

- q_v Air volume flow rate, dm³/s
- v_{al} Duct velocity (ø160 mm duct), m/s
- p_{tot} Total pressure loss, Pa
- ζ_{tot} Total pressure loss coefficient, -
- L_{W63...8000} Sound power level in the duct in octave bands, dB
- 63...8000 Centre frequencies of the octave bands, Hz
- L_W Sound power level in the duct, dB
- L_{WA} A-weighted sound power level in the duct, dB(A)



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Instruments used:

Instrument	Type code	Serial number	Calibrated
Micromanometer	Furness FC012	9802124	07/2021
Micromanometer	Furness FC012	110057	07/2021
Micromanometer	Furness FC012	9802125	07/2021
Barometer	Vaisala PTB220BAC2A1	W4230002	07/2021
Hygrometer	Rotronic HTT	8501156	11/2021
Temperature logger	Agilent 34970A	MY44071581	07/2021
Pistonphone	B&K 4228	3063558	01/2021
Microphone	B&K 4943	2415046	before measurements
Microphone preamplifier	B&K 2660	15040598	
Real-time analyser	Norsonic RT 830-2	11504	07/2020
Rotating microphone stand	B&K 3923	1678218	
Reverberation room	298 m ³		