

DECLARATION OF PERFORMANCE

No 025/07/2017

1. Unique identification code of the product:

Iris damper: GBL

2. Intended use:

Intender for steeples air flow control in ventilation systems

3. Manufacturer:

Alnor Systemy Wentylacji Sp. z o.o.

00-719 Warszawa ul. Zwierzyniecka 8b

Tel.: + 48 22 737 40 00, Fax.: + 48 22 737 40 04

4. Agent:

Not relevant

5. System of AVCP:

System 4

6. Standard:

EN 1506:2007 Ventilation for buildings - Sheet metal air ducts and fittings with circular cross-section – Dimensions.

EN 1751:2002 Ventilation for buildings – Air terminal devices – Aerodynamic testing of dampers and valves.

7. Notified body:

Not relevant

8. Declared performances:

Essential Characteristics	Declared performances	Notes
Diameter range	80 – 800 mm	

Sheet thickness	0,5 - 0,7 mm	
Tolerance for dimensions	Corresponds with requirements	
Appearance and quality	Corresponds with requirements	
Air flow rate q_v , Pressure drop P_t , Noise pressure level L_A , air flow velocity V	According to data sheet	

9. The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer:

Artur Kołacz

Product Manager

.....
 (Name and position)

Wola Mrokowska 05.07.2017

.....
 (Place and date of issue)



 (Signature)
 ALNOR-SYSTEMY WENTYLACJI Sp. z o. o.
 ul. Zwierzyniecka 8b, 00-719 Warszawa
 tel. +48 22 737 40 00, fax. +48 22 737 40 04
 NIP: 521-10-68-747, REGON: 010685817