Alnor Systemy Wentylacji Sp. z o.o.,
Aleja Krakowska 10, 05-552 Wola Mrokowska,
tel.: + 48 22 737 40 00, fax.: + 48 22 737 40 04,
e-mail: alnor@alnor.com.pl, www.alnor.com.pl.

DECLARATION OF PERFORMANCE
No 112/07/2017

1. Unique identification code of the product:

   Access door for round ducts: IPR, IPR-RRD
   Access door for square ducts: IPFQ, IPFQ-RD

2. Intended use:

   Accessing and inspection of ventilation and air conditioning ducts

3. Manufacturer:

   Alnor Systemy Wentylacji Sp. z o.o.
   00-719 Warszawa ul. Zwierzyniecka 8b
   Tel.: + 48 22 737 40 00, Fax.: + 48 22 737 40 04

4. Agent:

   Not relevant

5. System of AVCP:

   System 4

6. Standard:

   EN 12097:2007 Ventilation for buildings. Requirements for ductwork components to facilitate maintenance of ductwork systems.

7. Notified body:

   Not relevant

8. Declared performances:

Essential Characteristics	Declared performances	Notes
Diameter range for round doors	80 – 1600 mm	

Alnor Systemy Wentylacji Sp. z o.o.,
Aleja Krakowska 10, 05-552 Wola Mrokowska,
tel.: + 48 22 737 40 00, fax.: + 48 22 737 40 04,
e-mail: alnor@alnor.com.pl, www.alnor.com.pl.

Dimension range for square doors	180 – 700 mm	
Shape and dimensions	According to technical drawings	
Tolerance for dimensions	Corresponds with requirements	
Appearance and quality	Corresponds with requirements	

9. The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer:

Artur Kołacz Product Manager

……

(Name and position)

Wola Mrokowska 05.07.2017

……..

(Place and date of issue)

……

(Signature)

ALNOR-SYSTEMY WENTYLACJI Sp. z o.o.
ul. Zwierzyniecka 8B, 00-719 Warszawa
tel. +48 22 737 40 00, fax. +48 22 737 40 04
NIP: 521-10-68-747, REGON: 010685817